



BUFFALO WILD WINGS®

40484 Murrieta Hot Springs Rd.,
Murrieta, CA 92563

**Data Analysis Of IceCOLD® Test
Conducted On A Packaged Air Conditioning Unit and two Condensing
Units**

October 07, 2014



Increased Cooling Efficiency

Pre Test

Amp Draw
Normalized
Per Cooling
Degree Days

Post Test

**38% Less
Amp-hours Consumed
To Maintain Set-Point
Temperature**



Logged Data

Test parameters selected for measurements enable evaluating the potential for increased cooling efficiencies across varying ambient temperatures and heat loads. With this, the Supply and Return Air temperatures were controlled.




Areas that were logged and analyzed:

- 1 **Amp Draw** (1 minute intervals)
- 2 **Ambient Air Temperature** (1 minute intervals)
- 3 **Supply and Return Air Temperature** (1 minute intervals)
- 4 **Cooling Degree Days** (calculated)





Measurements Scene – Supply, Return & Ambient Temperatures



	AC-1			CDD
Temperature, degF	Avg OAT	SAT	RAT	BP=65 F
Pre-treatment	73.2	77.7	58.5	8.18
Post-treatment	87.2			22.2
Avg deltaT	14.05			

Presented comparison of Outdoor Air Temperatures before and after IceCold treatment indicates, that post-treatment measurement was performed at much warmer ambient conditions



Compressor Current and Ambient Temperature measurements at AC-1

Energy Consumed strongly depends on Ambient Temperature




Chart above represents relationship between electric current drawn by AC unit and ambient temperature.

Linear regression line and corresponding regression equation indicate strong current-temperature dependency.

That clearly requires to perform energy comparison in weather-normalized forms.



Pre- and Post-treatment measurements – energy use comparison with weather normalization

	Pre- AC-1	Pre- CU-1	Pre- CU-3
Amp-hrs/CDD	104.3	42.4	61.3
Amp-hrs	853.4	346.6	501.8
Hours ON	100.2	53.7	51.9
Avg Amps	8.5	6.5	9.7
	Post- AC-1	Post- CU-1	Post- CU-3
Amp-hrs/CDD	57.1	23.8	23.8
Amp-hrs	1,268.9	530.1	528.3
Hours ON	131.7	78.2	64.1
Avg Amps	9.6	6.8	8.2
Amp-hrs/CDD Sav	45.3%	43.7%	61.3%

IceCold treatment leads to >40% of savings in Amp-hours/CDD



Methodology - Data Comparison & Analysis



SIEMENS
REAL ESTATE
CBRE Energy Program
CB RICHARD ELLIS

MEASUREMENT & VALIDATION REPORT

Revision: 0A

Date: 4/21/2011

APPENDIX: DAILY (TOTALIZED) ELECTRICAL CONSUMPTION - PRE



Savings Calculations

The formula utilized to calculate the energy savings reduction (as a percentage) is the difference between the calculated baseline energy consumption per cooling degree day (CDD pre) and the calculated post-retrofit energy consumption per cooling degree day (CDD post).


$$\text{Amp-Hour Baseline} = \text{Amp-Hour Measured Pre} / \text{CDD pre},$$

$$\text{Amp-Hour Post} = \text{Amp-Hour Measured Post} / \text{CDD post}$$

$$\text{Percent Reduction} = (\text{Amp-Hour Baseline} - \text{Amp-Hour Post}) / \text{Amp-Hour Baseline}$$



Air Conditioning Unit AC-1 – field testing results for pre- and post- treatment





Charts above compare electric Currents drawn by AC-1 unit before and after IceCold treatment. Visual comparison indicates larger Amperage and longer operational time with after-treatment conditions. However, as earlier charts indicate, comparison shouldn't be performed on "intuitive, visual" basis.

Detailed quantitative analysis of weather-normalized energy usage clearly presents significant after-treatment energy savings, when measured in comparable ambient conditions (see below).




Condensing Unit CU-1- field testing results for pre- & post- treatment



Detailed quantitative analysis of weather-normalized energy usage clearly presents significant after-treatment energy savings, when measured in comparable ambient conditions.




Condensing Unit CU-2- field testing results for pre- & post- treatment



Detailed quantitative analysis of weather-normalized energy usage clearly presents significant after-treatment energy savings, when measured in comparable ambient conditions



Condensing Unit CU-3- field testing results for pre- & post- treatment



Detailed quantitative analysis of weather-normalized energy usage clearly presents significant after-treatment energy savings, when measured in comparable ambient conditions